

During the past months our water usage has increases considerable. We have therefore tested and recorded water meter readings having isolated water supply to the building and churchyard utility services (Kitchens, We's & Standpipes). The evidence recorded indicates that there is possibly more than one leak, and this appears to be worsening. The water meter dials continuing to record usage during the isolation test.

The metered building and churchyard utility services are supplied through approximately 250 meters of buried 21st century polyethylene pipework. Old metal pipework appears to be obsolete. There is no evidence of surface or internal water leakage. Current recordings indicate that we are leaking approximately 45 cubic meters of water per month. Our water services contract is with Castle Water at a cost of £1.1626 per cubic meter. This leakage is currently estimated to cost £52 a month, £624 a year.

Ecclesiastical insurance has agreed under the terms of our policy for their supplier (Auger) to find and fix the leakage.

